





# Circuit breaker, FA, 480V 60A, 3 pole, shunt trip

FA340601021

- Discontinued on: Nov 11, 2020
- ! End-of-service on: Dec 31, 2020

(!) Discontinued

#### Main

Product Or Component Type	Circuit breaker
Trip Unit Technology	Thermal-magnetic

### Complementary

•	
Line Rated Current	60 A
Number Of Poles	3P
Breaking Capacity Code	A
Mounting Mode	I-Line
Magnetic Hold Current	800 A
Magnetic Tripping Current	1450 A
Electrical Connection	Lugs, load I-Line connection, line
Terminal Identifier	AL50FA
Phase Connection	ABC
Height	6.4 in (162.56 mm)
Width	4.5 in (114.30 mm)
Depth	4.13 in (104.90 mm)
Circuit Breaker Application	HACR rated

#### **Environment**

Certifications	UL Listed
	CSA

## Ordering and shipping details

Category	01005-FA 480V BREAKER & SWITCH
Discount Schedule	DE2
Gtin	00785901255239
Returnability	No
Country Of Origin	MX

## **Packing Units**

DCE	t Type Of Package 1	Type Of Package 1

Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

Number Of Units In Package 1

- 1

## **Contractual warranty**

Warranty

18 months



**Green Premium<sup>TM</sup> label** is Schneider Electric's commitment to delivering products with best-inclass environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO<sub>2</sub> products.

**Guide to assessing product sustainability** is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium >

Guide to assess a product's sustainability >





Transparency RoHS/REACh

#### **Certifications & Standards**

Eu Rohs Directive	Pro-active compliance (Product out of EU RoHS legal scope)	
	EU RoHS Declaration	
Environmental Disclosure	Product Environmental Profile	
California Proposition 65	WARNING: This product can expose you to chemicals including: DINP, which is known to the State of California to cause cancer, and DIDP, which is known to the State of California to cause Birth Defects or other reproductive harm.For more information go to www.p65warnings.ca.gov	