

Additional SDE fault trip indication contact, MasterPact MTZ2/MTZ3 drawout, 1 changeover contact, standard 6A/240VAC

LV848475

Main

Range	MasterPact
Device Short Name	SDE
Device Application	Control
Range Compatibility	Masterpact MasterPact MTZ2 circuit breaker Masterpact MasterPact MTZ3 circuit breaker

Complementary

Auxiliary Contacts Type	Standard	
Signal Contacts Composition	1 NO/NC	
Mounting Mode	Drawout	
[Ith] Conventional Free Air Thermal Current	5 A	
Breaking Capacity	6 A AC-12 240/380 V AC 50/60 Hz 2 A AC-12 480 V AC 50/60 Hz 3 A DC-12 24/48 V DC 0.3 A DC-12 125 V DC 0.15 A DC-12 250 V DC	
Minimum Load	100 mA 24 V	

Ordering and shipping details

Gtin 3606480804533

Packing Units

Unit Type Of Package 1	PCE
Number Of Units In Package 1	1
Package 1 Height	1.38 in (3.5 cm)
Package 1 Width	1.57 in (4.0 cm)
Package 1 Length	2.87 in (7.3 cm)
Package 1 Weight	2.47 oz (70.0 g)

Price is "List Price" and may be subject to a trade discount – check with your local distributor or retailer for actual price.

Sustainability

Green PremiumTM label is Schneider Electric's commitment to delivering products with best-inclass environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO₂ products.

Guide to assessing product sustainability is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium >

Guide to assess a product's sustainability >

Well-being performance

Well-beilig performance		
Reach Free Of Svhc		
Mercury Free		
Rohs Exemption Information	Yes	
Reach Regulation	DEACh Paglavation	
Trough Regulation	REACh Declaration	
Eu Rohs Directive	Compliant with Exemptions	
China Rohs Regulation	China RoHS declaration Product out of China RoHS scope. Substance declaration for your information.	
California Proposition 65	WARNING: This product can expose you to chemicals including: DINP, which is known to the State of California to cause cancer, and DIDP, which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov	