

substation - S44 - Sepam series 40

59688

- Discontinued on: Jan 12, 2024
- ! To be end-of-service on: Dec 31, 2030

! Discontinued - Service only

Main

| Relay Application | Substation |
|---------------------------------------|---|
| Range Of Product | Sepam series 40 |
| Device Short Name | S44 |
| Control And Monitoring Type | Latching/acknowledgement ANSI code: 86 Logic discrimination ANSI code: 68 (option) Switching of groups of settings Annunciation ANSI code: 30 Circuit breaker/contactor control ANSI code: 94/69 Logic equation editor 100 operators |
| Metering Type | Phase current I1, I2, I3 RMS, residual current I0 Demand current I1, I2, I3, peak demand current IM1, IM2, IM3 Voltage U21, U32, U13, V1, V2, V3, residual voltage V0 Frequency Positive sequence voltage Vd/rotation direction-negative sequence voltage Vi Active, reactive, apparent power P,Q,S-peak demand power PM, QM, power factor Calculated active and reactive energy (+/- W.h, +/- VAR.h) Active and reactive energy by pulse counting (+/- W.h, +/- VAR.h) (option) |
| Network And Machine Diagnosis Type | Unbalance ratio/negative sequence current li Disturbance recording Tripping context Cable arcing fault detection Phase displacement |
| Switchgear Diagnosis Type | Cumulative breaking current Trip circuit supervision (option) Number of operations, operating time charging time (option) CT/VT supervision ANSI code: 60FL |

Complementary

| Type Of Measurement | Power factor | | |
|---------------------|--|--|--|
| | Energy | | |
| | Peak demand power | | |
| | Frequency | | |
| | Current | | |
| | Power (P,Q) | | |
| | Voltage | | |
| Protection Type | Recloser (4 cycles) ANSI code: 79 (option) | | |
| | Breaker failure ANSI code: 50BF (1) | | |
| | Undervoltage protection ANSI code: 27/27S (2) | | |
| | Overvoltage protection ANSI code: 59 (2) | | |
| | Phase overcurrent ANSI code: 50/51 (4) | | |
| | Earth fault/sensitive earth fault ANSI code: 50N/51N (4) | | |
| | Earth fault/sensitive earth fault ANSI code: 50G/51G (4) | | |
| | Negative sequence/unbalance ANSI code: 46 (2) | | |
| | Negative seguence overvoltage ANSI code: 47 (1) | | |

| Communication Port Protocol | Measurement readout (option) : Modbus |
|-----------------------------|---|
| | Remote indication and time tagging of events (option): Modbus |
| | Remote control orders (option) : Modbus |
| | Remote protection setting (option): Modbus |
| | Transfer of disturbance recording data (option) : Modbus |
| Input Output Max Capacity | 10 inputs + 8 outputs |
| Communication Compatibility | Modbus TCPIP |
| | DNP3 |
| | IEC 60870-5-103 |
| | IEC 61850 |
| | Modbus RTU |
| User Machine Interface Type | Advanced |
| | Remote |
| | Without |

Packing Units

| Unit Type Of Package 1 | PCE |
|------------------------------|----------|
| Number Of Units In Package 1 | 1 |
| Package 1 Height | 10.0 cm |
| Package 1 Width | 10.0 cm |
| Package 1 Length | 10.01 cm |
| Package 1 Weight | 1.0 ka |

Sustainability

Green PremiumTM label is Schneider Electric's commitment to delivering products with best-inclass environmental performance. Green Premium promises compliance with the latest regulations, transparency on environmental impacts, as well as circular and low-CO₂ products.

Guide to assessing product sustainability is a white paper that clarifies global eco-label standards and how to interpret environmental declarations.

Learn more about Green Premium >

Guide to assess a product's sustainability >

Well-being performance

| Reach Free Of Svhc | |
|----------------------------|--|
| Mercury Free | |
| Rohs Exemption Information | Yes |
| | |
| Reach Regulation | REACh Declaration |
| Eu Rohs Directive | Pro-active compliance (Product out of EU RoHS legal scope) EU RoHS Declaration |
| China Rohs Regulation | China RoHS declaration |