



# TeSys K contactor , 4P (4 NO) , AC, 1 <= 440 V 20 A , 110 V AC coil

LC7K090047F7

#### ! Discontinued

#### Main

Range Of Product	TeSys K	
Range	TeSys	
Product Name	TeSys K	
Device Application	Control	
Product Or Component Type	Contactor	
Device Short Name	LC7K	
Utilisation Category	AC-1	
Poles Description	4P	
Pole Contact Composition	4 NO	
[le] Rated Operational Current	20 A (at <50 °C) at <= 440 V AC AC-1 for power circuit 16 A (at <70 °C) at 690 V AC AC-1 for power circuit	
Signalling Circuit Frequency	<= 400 Hz	

## Complementary

Contactor Application	Resistive load
Control Circuit Voltage Limits	Operational: 0.851.1 Uc (at <50 °C)
	Drop-out: 0.10.75 Uc (at <50 °C)
Control Circuit Type	AC at 50/60 Hz silent
[Uc] Control Circuit Voltage	110 V AC 50/60 Hz
Connections - Terminals	Faston terminals 2 cable(s) - busbar cross section: 2.8 mm
	Faston terminals 1 cable(s) - busbar cross section: 6.35 mm
Electrical Durability	0.18 Mcycles 20 A AC-1 at Ue <= 440 V
Mechanical Robustness	Shocks contactor closed, on X axis: 10 Gn for 11 ms conforming to IEC 60068-2-27
	Shocks contactor closed, on Y axis: 15 Gn for 11 ms conforming to IEC 60068-2-27
	Shocks contactor closed, on Z axis: 15 Gn for 11 ms conforming to IEC 60068-2-27
	Shocks contactor opened, on X axis: 6 Gn for 11 ms conforming to IEC 60068-2-27
	Shocks contactor opened, on Y axis: 10 Gn for 11 ms conforming to IEC 60068-2-27
	Shocks contactor opened, on Z axis: 10 Gn for 11 ms conforming to IEC 60068-2-27
	Vibrations contactor closed: 4 Gn, 5300 Hz conforming to IEC 60068-2-6
	Vibrations contactor opened: 2 Gn, 5300 Hz conforming to IEC 60068-2-6
Standards	EN/IEC 60947-4-1
	GB/T 14048.4
	UL 60947-4-1
	CSA C22.2 No 60947-4-1
	JIS C8201-4-1
Ip Degree Of Protection	IP2X conforming to VDE 0106
Protective Treatment	TC conforming to IEC 60068
	TC conforming to DIN 50016

[Ui] Rated Insulation Voltage	Power circuit: 600 V conforming to UL 508  Power circuit: 690 V conforming to IEC 60947-4-1  Power circuit: 600 V conforming to CSA C22.2 No 14
[Uimp] Rated Impulse Withstand Voltage	8 kV
Overvoltage Category	III
Mounting Support	Plate Rail
Product Certifications	CB Scheme CCC UL CSA EAC
	CE UKCA
Ambient Air Temperature For Storage	-5080 °C
Operating Altitude	2000 m without derating
[Ue] Rated Operational Voltage	Power circuit: 690 V AC 50/60 Hz
[Ith] Conventional Free Air Thermal Current	20 A (at 50 °C) for power circuit
Irms Rated Making Capacity	110 A AC for power circuit conforming to NF C 63-110 110 A AC for power circuit conforming to IEC 60947
Rated Breaking Capacity	110 A at 415 V conforming to IEC 60947 110 A at 440 V conforming to IEC 60947 80 A at 500 V conforming to IEC 60947 110 A at 220230 V conforming to IEC 60947 110 A at 380400 V conforming to IEC 60947 70 A at 660690 V conforming to IEC 60947
Associated Fuse Rating	25 A gG at <= 440 V for power circuit 25 A aM for power circuit
Average Impedance	3 mOhm - Ith 20 A 50 Hz for power circuit
Inrush Power In Va	3 VA (at 20 °C)
Hold-In Power Consumption In Va	3 VA (at 20 °C)
Operating Time	3040 ms coil energisation and NO closing 30 ms coil de-energisation and NO opening
Safety Reliability Level	B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1 B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1
Mechanical Durability	10 Mcycles
Maximum Operating Rate	3600 cyc/h
Height	58 mm
Width	45 mm
Depth	57 mm
Net Weight	0.225 kg
Compatibility Code	LC7K
Environment	
[Icw] Rated Short-Time Withstand Current	90 A 50 °C - 1 s for power circuit  85 A 50 °C - 5 s for power circuit  80 A 50 °C - 10 s for power circuit  60 A 50 °C - 30 s for power circuit  45 A 50 °C - 1 min for power circuit  40 A 50 °C - 3 min for power circuit  20 A 50 °C ->= 15 min for power circuit
Heat Dissipation	3 W

Flame Retardance

V1 conforming to UL 94

Requirement 2 conforming to NF F 16-101

Requirement 2 conforming to NF F 16-102

## **Packing Units**

Unit Type Of Package 1	PCE
Number Of Units In Package 1	1

## **Contractual warranty**

Warranty 18 months